



SECTION/ELEVATION

NO SCALE

NOTES:

1. POST SHALL BE 6" MIN. DIA. LODGE POLE.
2. RAILS SHALL BE 3-1/2" MIN. DIA. LODGE POLE.
3. ALL RAILS TO BE SECURED TO POST WITH 20d HOT DIPPED GALV. NAILS.
4. ALL LUMBER TO BE CCA PRESSURE TREATED.
5. SUBGRADE AT FOOTINGS TO BE 90%(MINIMUM) COMPACTION.
6. CONCRETE FOOTINGS SHALL BE 470-C-2000 "CLASS B" CONCRETE.

Revised:	Original approval date: 12-5-75	CITY OF CHULA VISTA PUBLIC WORKS DEPARTMENT	
9-06-01 CVM	Redrawn By: ARR Date: 7-26-95		
	<i>Clifford Stevenson</i>	POST & RAIL FENCE	CVCS 16
	CITY ENGINEER Date: 11-7-02		